

ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE REGULATORY CONTACT RECORD

Date/Time: January 12, 2005 / 0700

Site Contact(s): Steve Nesta
Phone: 303-966-6386

Regulatory Contact: David Kruckek
Phone: 303-692-3328


Agency: CDPHE

Purpose of Contact: Regulatory Concurrence for Demolition of B444 Annex

Discussion

The State has reviewed the PDS data from VIA2 and agreed that it is sufficient for proceeding with limited demolition for B444 Annex. In addition, the CDPHE requested the following information on the specifics of the demolition; found in Work plan #T0112969. The CDPHE has agreed with the additional information and has concurred with proceeding with the demolition.

- The rad contaminated floor slab in room 179 and the corridor going to room 180B are covered with ½ inch plywood to protect and prevent the potential spread of contamination to the above slab structure during the demolition and load out of the structure.
- Demolition of the Annex consist of only rooms 182, 180, 181, 180B, 179 corridor, 179, 260, 281A, and 281.
- The West walls at column line "U" which are composed of rooms 143B, 143C, corridor from room 143K, rooms 183, and 148A are the original concrete wall of B444. These walls are spray-painted orange as a visible indication to the demolition crew that this wall is to remain in place.
- All window and door openings connecting the above have been framed and covered with ½ inch plywood at the line of separation between the Annex and the remaining B444 structure.
- The return air tunnels are painted on the floor surface as a visible indication to the demolition crew that there are voids under the floor during the demolition of the above slab structure. Once the structure has been size reduce and debris loaded out the slab over the tunnels and the walls will be demolished to a minimum of 3 feet below final grade. The remaining tunnels will be back filled with clean soil coming from the B664 area.
- The portions of the slab that do not meet unrestricted release criteria will be removed and not left in place.



1/2

Contact Record Prepared By: Steve Nesta

Required Distribution:

M. Aguilar, USEPA
S. Bell, DOE-RFPO
B. Birk, DOE-RFPO
C. Deck, K-H Legal
D. Foss, K-H 707/776/777
S. Garcia, USEPA
C. Gilbreath, K-H 771/774
S. Gunderson, CDPHE
J. Legare, DOE-RFPO

R. Leitner, K-H 371/374
J. Mead, K-H ESS
G. Morgan, DOE-RFPO
S. Nesta, K-H RISS
K. North, K-H ESS/MS
R. Schassburger, DOE-RFPO
D. Shelton, K-H ESS
C. Zahm, K-H Legal

Additional Distribution:

2/2